

Copy of the certificate regarding Water, Health and Sanitation issued by Medical Officer of Health, Gandhinagar Municipal Corporation

Letter No: GMC/0148/05/2026 Approved Date: 11-05-2026



The Urban Health Society

Gandhinagar Municipal Corporation

Pandit Dindayal Upadhyay Bhavan, First floor,
Behind Fire station, sector-17, Gandhinagar(Gujarat)Pin-382016

Email:moh.health2.gandhinagar@gmail.com

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No:GMC/TUHS/Certificate/File No.53/ /2026

DATE: /05/2026

It is certified that an inspection team headed by Dr.Kalpesh Goswami From Health Department Gandhinagar Municipal Corporation inspected, SERENITY SCHOOL FOR CHILDREN, K Raheja Road, Near Sant Vihar-3, Koba, Gandhinagar- 382007. On the basis of Water Test report bearing O.W.No. DL/GNR/486/of 2026 Dt:24/04/2026 of Gujarat water supply & Sewerage Board certified that the SERENITY SCHOOL FOR CHILDREN has safe drinking water Facilities for the students and members of staff of the institution and school is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/state/U.T.Govt.

The above valid for a period of 07/05/2026 to 06/05/2027

Signature with

seal:.....

Name: Dr. K. I. Goswami

Designation: Medical Officer of Health

To
Principal,
SERENITY SCHOOL FOR CHILDREN,
K Raheja Road, Near Sant Vihar-3, Koba,
Gandhinagar- 382007

Signature Not Verified

Signed by: DR. KALPESH PURI
ISHVARPURI GOSWAMI
Medical Officer of Health
Date: 2026.05.11
15:15:35 +5:30

File No: GMC/HLT/e-file/341/2026/1669/Health

Approved By: Medical Officer of Health, Health, GMC

Open the document in Adobe Acrobat DC to verify the E-sign



1/1


SERENITY SCHOOL FOR CHILDREN

PRINCIPAL

SERENITY SCHOOL FOR CHILDREN

CHAIRMAN


Copy of the Water Examination Report

DL/7.8/F-01				
	DISTRICT LABORATORY Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar			
Test Report				
Name & Address of Customer:- Serenity School For Children K Raheja Road Koba Gaam Gandhinagar				
Customer Reference No.:- Sample Submitted by :Customer Date of Sample Receipt :21-Apr-2026 Analysis Starting Date :22-Apr-2026 Analysis Completion Date :22-Apr-2026 Dicipline:Chemical Testing,Group:Drinking Water ULR -TC178482600000303F				
Test Report No.: 486/2026-27				
Sample ID : 486				
Main Source :Ground Water				
Location :Serenity School For Children				
Village :Koba				
Taluka :Gandhinagar				
Latitude :-				
Kindly find herewith the Analytical Results.				
Sample Type : Drinking Water				
Sr.No.	Parameter	Unit	Reference Method :	Analytical Value
1	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
2	Turbidity	NTU	APHA (24 th Ed.2023), Method: 2130 B	0.78
3	pH at 25°C	-	APHA (24 th Ed.2023) Method: 4500 H ⁺ B	8.14
4	Conductivity at 25°C	µS/cm	APHA (24 th Ed.2023) Method: 2510 B	331
5	Total Dissolved Solids	mg/l	APHA (24 th Ed.2023) Method: 2540 C	212
6	Total Hardness(as CaCO ₃)	mg/l	APHA (24 th Ed.2023) Method: 2340 C	132
7	Calcium (as Ca ⁺²)	mg/l	APHA (24 th Ed.2023) Method: 3500 Ca+2 B	24
8	Magnesium (as Mg ⁺²)	mg/l	APHA (24 th Ed.2023) Method: 3500-Mg+2 B	17
9	Chloride (as Cl ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-Cl - B	32
10	Sulphate (as SO ₄ ⁻²)	mg/l	APHA (24 th Ed.2023) Method: 4500-SO4-2 E	12
11	Nitrate (as NO ₃ ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-NO3- B	3.49
12	Fluoride (as F ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-F - C	0.15
13	Total Alkalinity(as CaCO ₃)	mg/l	APHA (24 th Ed.2023) Method: 2320 B	140
This Report is issued under the following terms & Condition : 1. This report is referring only to the tested sample and for applicable parameter. 2. The sample will be destroyed after retention time unless otherwise specified specially. 3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law. 4. Please refer back page for IS 10500:2012 (2nd Revision) limits.				
Reviewed by:  Prachi Patel (Technical Manager)		Issued By:  Khyati Nayak (Quality Manager) Authorized Signatory		
				
End of the Test Report				
O.W.No. DL/GNR/ 286 /of 2026, Dt. 24/4/2026. Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar E-mail: districtlabgandhinagar@gmail.com				

SERENITY SCHOOL FOR CHILDREN


PRINCIPAL

SERENITY SCHOOL FOR CHILDREN


CHAIRMAN



DISTRICT LABORATORY
GUJARAT JALSEVA TRAINING INSTITUTE
GUJARAT WATER SUPPLY & SEWERAGE BOARD
SECTOR - 15, 'G' Road, GANDHINAGAR - 382016



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address:-

Serenity School For Children
K Raheja Road, Koba Gaam
Gandhinagar

Sender's Ref.No:

Date of Receipt at Lab. /
Arrival Date:

21-Apr-26

Sample Collected By:

Customer

Lab Ref. i.e. BW No.

478

Date of Collection

21-Apr-26

Date of Commencing Examination:

21-Apr-26

Source of Water Sample

R.O. Water

Serenity School For Children

Village

Koba

Habitation

Koba

Taluka

Gandhinagar

District

Gandhinagar

Membrane Filtration Method,
IS-15185:2016, ISO 9308-1:2014 for Total Coliform

< 1

Membrane Filtration Method, IS-15185:2016,
ISO 9308-1:2014 for Therotolerant Fecal Coliform (*E.coli*)

< 1

Opinion For Potability As Per The BIS:10500:2012

Safe

Important Note:-

*Sample should be collected in sterile BOD bottle.

*"Unsafe" :- Proper Disinfection may render it safe.

*Presence of Coliform in water sample indicates the need of proper Disinfection.

NOTE :

Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision.

*All Water Intended for Drinking -

(a) *E.coli* or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

*Treated Water Entering the Distribution system & Treated Water in the Distribution system -

(a) *E.coli* or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

(b) Total coliform bacteria shall not be detectable in any 100ml sample.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.

2) This Report should not be taken as a basis to getting license from any Government authority.

3) After Collection of Bacteriological sample, it must be preserved at (3±3)°C and submitted to laboratory within 24hrs.

Analysed By :
Microbiologist

R



Lab Incharge

Outward No.: GJTI/Dist.Lab/BWT 478 / of 2026, Date: 24 / 4 / 2026

SERENITY SCHOOL FOR CHILDREN

PRINCIPAL

SERENITY SCHOOL FOR CHILDREN

CHAIRMAN